



TREZOR TEST s. r. o.  
Na Vršku 67, 250 67 Klecany, Czech Republic

CERTIFICATION BODY No. 3025  
ACCREDITED BY  
THE CZECH ACCREDITATION INSTITUTE

## CERTIFICATE OF CONFORMITY

Registration number: TT - 106/2023

for  
UAB Trikdis  
Draugystes st. 17, Kaunas LT-51229, Lithuania

**PRODUCT:** Cellular communicator for the fire control panel  
type G17F  
Producer: UAB Trikdis  
Draugystes st. 17, Kaunas LT-51229, Lithuania  
CZ-CPA 27.90.11

**CLASSIFICATION:** The product is in accordance with the certification schema CS TT 1a/2020 (based on  
scheme 1a EN ISO/IEC 17067:2013, based on testing).

and in conformity with requirements of

EN 50131-6:2017/A1:2021, EN 50131-10:2014, EN 50136-1:2012/A1:2018, EN 50136-2:2013,  
EN 50131-1:2006/A1:2009/A2:2017/A3:2020 (see cl. 4.2)

### Security Grade 4, Environmental Class II, Categories SP5 (GSM – GPRS)

The certificate is issued within the scope of accreditation granted by certificate No. 77/2022 issued by  
ČIA on 14 February 2022 on the basis of certification protocol No. CE 44/2023.

Chairman of the Certification board  
CO No. 3025  
Ing. Ladislav Polák

Deputy chairman of the Certification board  
CO No. 3025  
Ing. Daniela ČÍŽKOVÁ

Date of publication:

Certification date:

Certification expiration date:



16.03.2023

16.03.2023

16.03.2026

This Certificate of Conformity may be used and reproduced in unchanged form only.